



LEGEND:

1. ISOLATION VALVES - MUST BE SAME SIZE AS WATER SERVICE LINES.
2. 15MM WATER METER (INSTALLED BY CITY OF REGINA METER SHOP STAFF)
3. WATER LINE SUPPORTS.

NOTES:

1. PIPING MATERIALS AND INSTALLATION MUST COMPLY WITH THE CANADIAN PLUMBING CODE AND THE CITY OF REGINA STANDARD CONSTRUCTION SPECIFICATIONS.
2. WATER METERS SHALL BE INSTALLED HORIZONTALLY ALLOWING CONVENIENT ACCESS TO THE METER AT ALL TIMES AND WITH A CLEAR SPACE OF AT LEAST 460MM AROUND THE METER.
3. ISOLATING VALVES TO BE INSTALLED ON BOTH SIDES OF THE WATER METER, BEING THE INLET OR UPSTREAM SIDE AND THE OUTLET OR DOWNSTREAM SIDE. EACH VALVE TO BE INSTALLED WITHIN 300MM OF THE WATER METER.
4. WATER LINE SUPPORTS SHALL BE INSTALLED ON BOTH SIDES OF THE WATER METER, WITH EACH SUPPORT TO BE INSTALLED WITHIN 450MM OF THE WATER METER.

Date	Revisions	By
Sep/10	PROPOSED STANDARD FOR REVIEW	AH



CONSTRUCTION STANDARDS		
15MM RESIDENTIAL WATER METER INSTALLATION		
Designed By:	Approved: Kelly Wyatt	
Date: Jan/11	Scale: NTS	W-37
Digital File: Stdw-37.dwg		