

2016 to 2024 Asbestos Fibres in Drinking Water

Below are the asbestos results from each year, along with the location of each test. Each result includes a detection threshold, which is the smallest amount that can be found with the laboratory testing method. The test method follows the standard EPA 100.2, which is set by the United States Environmental Protection Agency (US EPA). This threshold can change year to year depending on the laboratory's accreditation. All testing results are shown in MFL, which is a measure of million fibres per litre of water tested.

2024

Total Asbestos (MFL) ^a	Testing Results	Detection Threshold	Health Canada Guideline Water Quality Objective
1920 McAra Street	Non-detect	0.18	Not Regulated
2640 31 st Avenue	Non-detect	0.18	
1109 14 th Avenue	Non-detect	0.18	
2626 Dewdney Ave. E	Non-detect	0.18	
68 Massey Road	Non-detect	0.18	
1201 Ross Avenue	Non-detect	0.18	
13 th Ave. & Albert St.	Non-detect	0.18	
560 Elphinstone Street	Non-detect	0.18	
35 Davin Crescent	Non-detect	0.18	
815 Assiniboine Ave. E.	Non-detect	0.18	

a. MFL is million of fibres per litre

2023

Total Asbestos (MFL)	Testing Results	Detection Threshold	Health Canada Guideline Water Quality Objective
132 Victoria Avenue	Non-detect	0.18	Not Regulated
1109 14 th Avenue	Non-detect	0.18	
2626 Dewdney Ave. E.	Non-detect	0.18	
13 th Ave. & Albert St.	Non-detect	0.18	

2022

Total Asbestos (MFL)	Testing Results	Detection Threshold	Health Canada Guideline Water Quality Objective
110 Kress Street	Non-detect	0.16	Not Regulated
132 Victoria Avenue	Non-detect	0.16	
2640 31 st Avenue	Non-detect	0.16	
1109 14th Avenue	Non-detect	0.16	
2626 Dewdney Ave. E	Non-detect	0.16	
1101 Kramer Boulevard	Non-detect	0.16	
1201 Ross Avenue	Non-detect	0.16	
13 th Ave. & Albert St.	Non-detect	0.16	
560 Elphinstone Street	Non-detect	0.16	
35 Davin Crescent	Non-detect	0.16	
815 Assiniboine Ave. E.	Non-detect	0.16	

2021*

Total Asbestos (MFL)	Testing Results	Detection Threshold	Health Canada Guideline Water Quality Objective
110 Kress Street	Non-detect	0.16	Not Regulated
132 Victoria Avenue	Non-detect	0.16	
2640 31 st Avenue	Non-detect	0.16	
1109 14th Avenue	Non-detect	0.16	
2626 Dewdney Ave. E	Non-detect	0.16	
1101 Kramer Boulevard	Non-detect	0.16	
1201 Ross Avenue	Non-detect	0.16	
13 th Ave. & Albert St.	Non-detect	0.16	
560 Elphinstone Street	Non-detect	0.16	
35 Davin Crescent	Non-detect	0.16	
815 Assiniboine Ave. E.	Non-detect	0.16	

*Samples for 2021 data were taken on Jan 4, 2022

2020

Total Asbestos (MFL)	Testing Results	Detection Threshold	Health Canada Guideline Water Quality Objective
110 Kress Street	Non-detect	0.16	Not Regulated
1775 McDonald Street	Non-detect	0.16	
2640 31 st Avenue	Non-detect	0.16	
1109 14 th Avenue	Non-detect	0.16	
130 Brotherton Avenue	Non-detect	0.16	
68 Massey Road	Non-detect	0.16	
1201 Ross Avenue	Non-detect	0.16	
13 th Ave. & Albert St.	Non-detect	0.16	
241 1 st Avenue N.	Non-detect	0.16	
35 Davin Crescent	Non-detect	0.16	
815 Assiniboine Ave. E.	Non-detect	0.16	

2019

Total Asbestos (MFL)	Testing Results	Detection Threshold	Health Canada Guideline Water Quality Objective
1109 14 th Avenue	Non-detect	0.17	Not Regulated

2018

Total Asbestos (MFL)	Testing Results	Detection Threshold	Health Canada Guideline Water Quality Objective
1109 14 th Avenue	Non-detect	0.17	Not Regulated

2017

Total Asbestos (MFL)	Testing Results	Detection Threshold	Health Canada Guideline Water Quality Objective
1109 14 th Avenue	Non-detect	0.17	Not Regulated

2016

Total Asbestos (MFL)	Testing Results	Detection Threshold	Health Canada Guideline Water Quality Objective
1109 14 th Avenue	Non-detect	0.17	Not Regulated